



Prüfzentrum für Bauelemente

Dipl.-Ing. (FH) Rüdiger Müller

PfB ♦ Lackermannweg 24 ♦ D-83071 Stephanskirchen

Fenster • windows
Rollläden • shutters
Türen + Tore • doors
Fassaden • curtain walling
Baubeschläge • building hardware

February 27, 2015

Letter of Result

Initial type testing (ITT) of performance characteristics in accordance with EN 14351-1 :2006 + A1 : 2010 “Windows and doors - Product standard, performance characteristics - Part 1: Windows and external pedestrian doorsets without resistance to fire and/or smoke leakage characteristics – German version EN 14351-1:2006 + A1:2010”

Applicant	Ersaş Alüminyum Veliköy Organize Sanayi Böl. 4.Cad. No:21 Çerkezköy-Tekirdağ-Türkiye		
Type	Tilt and turn single casement window with fixed side part, Aluminum, Double glazing		
System	Pascal Series		
Dimension	Total outside dimensions (W x H)	max. 1550 mm x 1550 mm	
	Casement (W x H)	max. 690 mm x 1395 mm	
Results	EN 1026 Air Permeability	EN 12207	Class 4
	EN 1027 Water tightness	EN 12208	Class E900
	EN 12211 Resistance to wind load	EN 12210	Class C5/B5

This Letter is not a certificate for CE-marking.

Nedret Sürmeli
General Manager

PfB
Danışmanlık Özel Eğitim Denetim Yapı Mlz.
Laboratuvar Hizmetleri Tic. Ltd. Şti
10045 Sk. No :7 AOSB Cigli / İZMİR
TEL 0232 328 10 44 FAX 0232 328 10 22
Cigli V.D. : 729 050 70 72

PfB GmbH & Co. Prüfzentrum für Bauelemente KG
AG Traunstein HRA 8871
Lackermannweg 24, 83071 Stephanskirchen
phG PfB Verwaltungs GmbH
Geschäftsführer: Matthias Demmel, Rüdiger Müller
AG Traunstein HRB 16490

Telefon +49 (0) 80 36 / 67 49 47 0
Telefax +49 (0) 80 36 / 67 49 47 28
www.pfb-rosenheim.de
info@pfb-rosenheim.de

Sparkasse Rosenheim
Bankleitzahl 711 500 00
Kontonummer 500 556 741
Steuer-Nr.156/172/13009
UST-IdNr. DE245353602



Anerkannte Prüfstelle
Landesbauordnung
BAY 33
Notified Body
No. 1644